

Request for Quotation / 報價請求

Subject:	Dismantle Access Control Readers and Install Break Glass Unit		
From/由:	Mr. Kim Wong / Patrick So	E-mail/電郵	kimwong@aims.com.mo
Tel/電話:	853-8598 8717 / 8898 2369	Fax/傳真:	853-8598 8711
Date/日期:	04-Dec-2019	Ref:	055-2019-Q

煩請按下列要求報價：

No.	Item / Model / Description	Qty.
Dismantle Access Control Readers and Install break glass units with local alarm buzzer alarm and modifying existing event log alarm message in reference to the emergency stair cases of PTB North Extension message type. Details as below:		
1.	<p>i) Dismantle the following ACS Cards Readers and cover with face-plate on the hole once the readers being removed and ii) install break glass with the installation of local buzzer alarm and real time event log on activation of break glass unit in ACS monitoring display as well as modification on location of alarm message</p> <p>Arrival: R134, R151, R159, R181 Departure: R305, R308 Mezzanine: R426, R428</p>	1
2.	<p>Arrival – Installation of one break glass unit at door #10141 (R185 location as attached) with local buzzer alarm and real time event logo on activation of break glass unit in ACS monitoring display as well as modification on location of alarm message.</p> <p>Roof – Installation of one break glass unit i) inside emergency staircase #4, ii) inside emergency staircase #5, and iii) two break glass units inside emergency staircase #3 with local buzzer alarm and real time event log on activation of break glass unit in ACS monitoring display as well as modification on location of alarm message.</p> <p>Relocate card reader R505 outside emergency staircase #3.</p>	1

條款:

1. 報價時請列明所有條款
2. 報價請以澳門幣結算及付款方式
3. 註明完成項目週期